

TEST CERTIFICATE

Certificate number: TC-J0091

Client: Liang Chew Hardware Pte Ltd

133 Kitchener Road
Singapore 208517

Product: Kombi Claw

Brand / Model: Norika / HUBKV


Detail: Nominal Diameter (mm): 50, 80, 100, 150, 200 and 250

Specification: Per Client's Specification
Hydrostatic Test:
DN 50 tested to 7 bars
DN 80, 100 and 150 tested to 5 bars
DN 200 tested to 2.5 bars
DN 250 tested to 2 bars

Test Report 1920458-OYC, 1920297-OYC, 21601526/01-MBM,
21601526/02-MBM

Summary

A sample of product submitted was tested and found to comply with the test requirements of the above standard(s).


Head, Certification
Singapore Test Lab Pte Ltd

Date of Original Issue:

30 July 2019

Date of Last Revision:

31 May 2021

Date of Expiry:

29 July 2023

This Certificate is part of the listed full report(s) and should be read in conjunction with it. This Certificate remains the property of Singapore Test Lab Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the Terms and Conditions of Singapore Test Lab Pte Ltd.



Singapore Test Lab is an ISO / IEC 17065 Certification Body

Singapore Test Lab Pte Ltd. 10B Enterprise Road, Singapore 629828. Telephone: 6353 6393 Fax: 6353 6395

